

# HK7 Series PRESSURE • DATASHEET•



## **HK7 Series** Intelligent High-precision Monocrystalline Differential Pressure Transmitters



#### Profile

HK7 series intelligent pressure/differential pressure transmitters, the central sensing unit adopts the world's leading high-precision silicon pressure and differential pressure sensor technology and packaging process. The single crystal silicon pressure and differential pressure sensor is located at the top of the metal body, away from the contact surface of the medium. To achieve mechanical isolation and thermal isolation; The sensor lead of glass sintering unit realizes high-strength electrical insulation with the metal substrate, which improves the flexibility of electronic circuits and the ability to withstand transient voltage protection. The circuit adopts a modular design with a microprocessor as the core and assisted by advanced digital isolation technology, so that the instrument has extremely high anti-interference and stability.

The Hart protocol is used for communication, which can be remotely operated through a Hart handheld communicator or a computer installed with Hart software to complete the measurement information configuration. At the same time, the digital compensation technology is used, and the transmitter is compensated through the built-in temperature sensor to improve the accuracy, temperature drift is reduced and features good long-term stability and high reliability. The most user-friendly design of the external one-key reset function meets the requirements of safe operation in hazardous situations. The shortcut menu is convenient for operation, and can complete all parameter settings, which comprehensively improves the performance of the transmitter.



#### **Features**

- ♦ Advanced monocrystalline silicon pressure sensor technology and packaging technology adopted;
- ♦ Modularization design with microprocessor as the core and assisted by advanced digital isolation technology, which makes it with high anti-interference and stability;
- ♦ Powerful 24-bit ADC achieves high precision;
- ♦ Innovative dual compensation technology, 0.075% high precision.

#### **Function Parameters**

| Range limit       Within the upper and lower limits of the measuring range, it can be adjusted arbitrarily. It is recommended to select a range code with the lowest possible turndown ratio to optimize performance         Zero point setting       Zero point and range can be adjusted to any value within the measurement range in the table, as long as: calibration range ≥ minimum range         Influence of installation location       The change of the installation position perpendicular to the diaphragm surface will not cause the zero drift effect. If the installation position and the diaphragm surface change more than 90°, the zero position in the range of <0.4kPa will be affected. It can be adjusted by adjusting the zero and there is no impact on the range.         Output       Two-wire system 4-20mA, in line with NAMIR NE43 specification, superimposed digital signal (Hart protocol) Linear or square root output is optional.         Output signal limit       Imin=3.9mA, Imax=21.0mA         Fault warning       If the sensor or circuit fails, the automatic diagnosis function will automatically output 3.9 or 21.0mA (user can pre-set)         Alarm current       Low alarm mode (minimum): 3.9mA         High report mode (maximum)       21 mA         Response time       The damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio. The additional adjustable time constant is: 0~100s         Preheating time       <15s |                     |   |
|---|---------------------|---|
| Influence of installation location  The change of the installation position perpendicular to the diaphragm surface will not cause the zero drift effect. If the installation position and the diaphragm surface change more than 90°, the zero position in the range of <0.4kPa will be affected. It can be adjusted by adjusting the zero and there is no impact on the range.  Two-wire system 4-20mA, in line with NAMIR NE43 specification, superimposed digital signal (Hart protocol) Linear or square root output is optional.  Output signal limit  Fault warning  If the sensor or circuit fails, the automatic diagnosis function will automatically output 3.9 or 21.0mA (user can pre-set)  Alarm current  High report mode (maximum)  Alarm current default setting  The damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio.  The additional adjustable time constant is: 0~100s  | Range limit         | arbitrarily. It is recommended to select a range code with the lowest possible  |
| Influence of<br>installation locationwill not cause the zero drift effect. If the installation position and the diaphragm<br>surface change more than 90°, the zero position in the range of <0.4kPa will be<br>affected. It can be adjusted by adjusting the zero and there is no impact on the<br>range.OutputTwo-wire system 4-20mA, in line with NAMIR NE43 specification, superimposed<br>digital signal (Hart protocol)<br>Linear or square root output is optional.Output signal limitImin=3.9mA, Imax=21.0mAFault warningIf the sensor or circuit fails, the automatic diagnosis function will automatically<br>output 3.9 or 21.0mA (user can pre-set)Alarm currentLow alarm mode (minimum): 3.9mAHigh report mode<br>(maximum)21 mAAlarm current<br>default settingHigh alarm modeResponse timeThe damping constant of the amplifier component is 0.1s; the time constant of the<br>sensor is 0.1 to 1.6s, depending on the range and the range ratio.<br>The additional adjustable time constant is: 0~100s  | Zero point setting  | , ,   |
| Output       digital signal (Hart protocol)         Linear or square root output is optional.         Output signal limit       Imin=3.9mA, Imax=21.0mA         Fault warning       If the sensor or circuit fails, the automatic diagnosis function will automatically output 3.9 or 21.0mA (user can pre-set)         Alarm current       Low alarm mode (minimum): 3.9mA         High report mode (maximum)       21 mA         Alarm current default setting       High alarm mode         Response time       The damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio. The additional adjustable time constant is: 0~100s  |                     | will not cause the zero drift effect. If the installation position and the diaphragm surface change more than 90°, the zero position in the range of <0.4kPa will be affected. It can be adjusted by adjusting the zero and there is no impact on the |
| Fault warning  If the sensor or circuit fails, the automatic diagnosis function will automatically output 3.9 or 21.0mA (user can pre-set)  Low alarm mode (minimum): 3.9mA  High report mode (maximum)  Alarm current default setting  The damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio.  The additional adjustable time constant is: 0~100s  | Output              | digital signal (Hart protocol)  |
| Alarm current  High report mode (minimum): 3.9mA  Alarm current  High alarm mode  (maximum)  Alarm current  default setting  The damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio.  The additional adjustable time constant is: 0~100s   | Output signal limit | Imin=3.9mA, Imax=21.0mA   |
| High report mode (maximum)  Alarm current default setting  The damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio. The additional adjustable time constant is: 0~100s  | Fault warning       | · ·   |
| (maximum)21 mAAlarm current<br>default settingHigh alarm modeResponse timeThe damping constant of the amplifier component is 0.1s; the time constant of the<br>sensor is 0.1 to 1.6s, depending on the range and the range ratio.<br>The additional adjustable time constant is: 0~100s   | Alarm current       | Low alarm mode (minimum): 3.9mA   |
| default settingThe damping constant of the amplifier component is 0.1s; the time constant of the sensor is 0.1 to 1.6s, depending on the range and the range ratio. The additional adjustable time constant is: 0~100s  |                     | 21 mA   |
| Response time sensor is 0.1 to 1.6s, depending on the range and the range ratio. The additional adjustable time constant is: $0\sim100s$  |                     | High alarm mode   |
| Preheating time <15s  | Response time       | sensor is 0.1 to 1.6s, depending on the range and the range ratio.  |
|   | Preheating time     | <15s  |



#### Performance Parameters

| Measuring medium              | Gas, steam, liquid   |
|-------------------------------|--|
| Accuracy                      | ±0.2%,±0.075%,±0.1%(Including linearity, hysteresis and      |
|                               | repeatability from zero)                                     |
| Stability                     | ±0.1%/3 years  |
| Ambient temperature influence | ≤±0.04%URL/10°C  |
| Influence of static pressure  | ±0.05%/10MPa   |
| Power supply                  | 10~36Vdc(24Vdc recommended)                                  |
| Power influence               | $\pm 0.001\%/10V$ (10 $\sim$ 36Vdc), which can be negligible |
| Ambient temperature           | -40℃ ~85℃  |
| Measuring medium temperature  | -40℃~120℃  |
| Storage temperature           | -40℃ ~105℃   |
| Display                       | LCD, OLED  |
| Module temperature shown on   | -20°C~70°C (LCD), -40°C~80°C (OLED)                          |
| display                       |  |
| Explosion-proof rating        | Exd II CT6 , Exia II CT4                                     |
| IP Rating for Housing         | IP67   |

#### Overload and static pressure

|   | Range  | Unilateral overload<br>(negative end) | Unilateral overload<br>(positive end) | Bilateral static<br>pressure |
|---|--------|---------------------------------------|---------------------------------------|------------------------------|
| A | 1KPa   | 16MPa                                 | 16MPa                                 | 40MPa                        |
| В | 6КРа   | 16MPa                                 | 16MPa                                 | 40MPa                        |
| С | 40КРа  | 25MPa                                 | 25MPa                                 | 40MPa                        |
| D | 400KPa | 25MPa                                 | 25MPa                                 | 40MPa                        |
| Е | 4MPa   | 25MPa                                 | 25MPa                                 | 40MPa                        |

# **HK71** Smart Direct-mounted Gauge Pressure/Absolute Pressure Transmitter

#### Gauge pressure range and range

| Range code | Measuring range(KPa) | Accuracy/Stability            |
|------------|----------------------|-------------------------------|
| A          | -6~6                 |                               |
| В          | -40~40               |                               |
| С          | -100~100             | ±0.075%F.S of the range/      |
| D          | -100~400             | The maximum error per year is |
| Е          | -100~4000            | ±0.1% of range                |
| F          | -100~40000           |                               |



#### Absolute pressure range and range

| Range code | Measuring range(KPa) | Accuracy/Stability            |
|------------|----------------------|-------------------------------|
| A          | 0~40                 | ±0.075%F.S of the range/      |
| В          | 0~250                | The maximum error per year is |
| С          | 0~2000               | ±0.1% of range                |


#### Gauge pressure overload limit

| Range      | 1KPa | 6КРа | 40KPa | 100KPa | 400KPa | 4000KPa | 40000KPa |
|------------|------|------|-------|--------|--------|---------|----------|
|            | Α    | В    | С     | D      | Е      | F       | G        |
| Load limit | 1MPa | 2МРа | 5МРа  | 7МРа   | 9МРа   | 10MPa   | 50MPa    |

#### Absolute pressure overload limit

| Range      | 40KPa | 250KPa | 2000KPa |
|------------|-------|--------|---------|
|            | A     | B      | C       |
| Load limit | 1MPa  | 4MPa   | 10MPa   |

#### Dimensions







#### How to Order

| Code | Туре    | Туре                                |          |         |          |                            |                      |   |  |
|------|---------|-------------------------------------|----------|---------|----------|----------------------------|----------------------|---|--|
| GP   | Smart I | Pressure                            | e Transm | itter   |          |                            |                      |   |  |
| AP   | Smart A | Smart Absolute Pressure Transmitter |          |         |          |                            |                      |   |  |
|      | Code    | Gauge                               | Pressure | e Range | (КРа)    | Absolut                    | e Pressure Range     | e (KPa)                                   |  |
|      | A       | 0~1~6                               |          |         |          |                            |                      |   |  |
|      | В       | 0~6~40                              | )        |         | 0~40~250 |                            |                      |   |  |
|      | С       | 0~40~1                              | 100      |         |          | 0~250~2                    | 2000                 |   |  |
|      | D       | 0~100                               | ~400     |         |          |                            |                      |   |  |
|      | Е       | 0~400                               | ~4000    |         |          |                            |                      |   |  |
|      | F       | 0~4000                              | 0~40000  |         |          |                            |                      |   |  |
|      |         | Code                                | Output   | signal  |          |                            |                      |   |  |
|      |         | Н                                   | 4~20m    | ıA      |          |                            |                      |   |  |
|      |         | S                                   | 4~20m    | A+Hart  |          |                            |                      |   |  |
|      |         |                                     | Code     | Display | 7        |                            |                      |   |  |
|      |         |                                     | M1       | LCD     |          |                            |                      |   |  |
|      |         |                                     | M2       | OLED(   | Low temp | perature re                | esistant -40℃)       |   |  |
|      |         |                                     |          | Code    | Process  | Connection                 | on                   |   |  |
|      |         |                                     |          | C1      | M20×1    | .5 male                    |                      |   |  |
|      |         |                                     |          | C2      | G1/2"    | male                       |                      |   |  |
|      |         |                                     |          | С3      | G1/4"    | male                       |                      |   |  |
|      |         |                                     |          | C4      | 1/2" N   | PT male                    |                      |   |  |
|      |         |                                     |          | C5      | 1/2" N   | PT female                  |                      |   |  |
|      |         |                                     |          | Т       | Special  | request                    |                      |   |  |
|      |         |                                     |          |         | Code     | Hazardou                   | ıs location certifi  | cation (do not fill in for ordinary type) |  |
|      |         |                                     |          |         | E0       | Non-expl                   | osion proof          |   |  |
|      |         |                                     |          |         | E1       | Flamepro                   | oof, Exd II CT6      |   |  |
|      |         |                                     |          |         | 12       | Intrinsica                 | ılly safe, Exia II C | T4  |  |
|      |         |                                     |          |         |          | Code Electrical connection |                      |   |  |
|      |         |                                     |          |         |          | D1 M20×1.5                 |                      |   |  |
|      |         |                                     |          |         |          | D2                         | User specified       |   |  |
|      |         |                                     |          |         |          |                            | Code                 | Special requirement                       |  |
|      |         |                                     |          |         |          |                            | Т                    | User specified                            |  |
| GP   | A       | Н                                   | M1       | C1      | E1       | D1                         | Т                    | Model No. example                         |  |




### **HK75** Intelligent High-precision Monocrystalline Differential Pressure Transmitter


#### **Measuring Range**

| Range code | Measuring range(KPa) | Accuracy/Stability                           |
|------------|----------------------|--|
| A          | -1~1                 |  |
| В          | -6~6                 |  |
| С          | -40~40               | ±0.075%F.S of the range;                     |
| D          | -100~100             | The maximum error per year is ±0.1% of range |
| Е          | -100~400             | year is 2012/2 of fullge                     |
| F          | -100~4000            |  |



#### Dimensions





How to Order

## • DATASHEET •

#### PRESSURE MEASUREMENT

| Code     | Type |            |          |           |  |                  |           |         |                      |             |   |
|----------|------|------------|----------|-----------|--|------------------|-----------|---------|----------------------|-------------|---|
| DP       |      | Differenti | al Press | ure Senso | or   |                  |           |         |                      |             |   |
|          | Code | DP Rang    | e (KPa)  |           |  |                  |           |         |                      |             |   |
|          | Α    | 0~0.2~1    |          |           |  |                  |           |         |                      |             |   |
|          | В    | 0~1~6      |          |           |  |                  |           |         |                      |             |   |
|          | С    | 0~6~40     |          |           |  |                  |           |         |                      |             |   |
|          | D    | 0~40~1     | .00      |           |  |                  |           |         |                      |             |   |
|          | Е    | 0~100~     | 400      | 0         |  |                  |           |         |                      |             |   |
|          | F    | 0~400~     | 4000     |           |  |                  |           |         |                      |             |   |
|          |      | Code       | Output   | Signal    |  |                  |           |         |                      |             |   |
|          |      | Н          | 4~20n    | nA        |  |                  |           |         |                      |             |   |
|          |      | S          | 4~20n    | nA+Hart   |  |                  |           |         |                      |             |   |
|          |      | J          |          | root 4~   |  |                  |           |         |                      |             |   |
|          |      |            | Code     | Display   | 7  |                  |           |         |                      |             |   |
|          |      |            | M1       | LCD       |  |                  |           |         |                      |             |   |
|          |      |            | M2       |           |  | erature r        |           | 40℃)    |                      |             |   |
|          |      |            |          | Code      |  | e Connec         | tion      |         |                      |             |   |
|          |      |            |          | CO        | NPT1/4   |                  |           |         |                      |             |   |
|          |      |            |          | C1        | NPT1/2   |                  |           |         |                      |             |   |
|          |      |            |          | C2        | M20×1.5  |                  |           |         |                      |             |   |
|          |      |            |          | C3        | Integrated three valve group  Structure material |                  |           |         |                      |             |   |
|          |      |            |          |           | Code   |                  | e materia | 1       | rain /archa          | ct          | Dianhraam                               |
|          |      |            |          |           | 21   | Flange<br>304 SS |           | 304 SS  | rain/exhau           | ડા          | Diaphragm<br>316 SS                     |
|          |      |            |          |           | 22   | 316 SS           |           | 316 SS  |                      |             | 316 SS                                  |
|          |      |            |          |           | 23   | 316 SS           |           | 316 SS  |                      | Hastelloy C |   |
|          |      |            |          |           | 24   | 316 SS           |           | 316 SS  |                      |             | Monel alloy                             |
|          |      |            |          |           | 25   | 316 SS           |           | 316 SS  |                      |             | Tantalum                                |
|          |      |            |          |           | 26   | Hastello         | v C       | Hastell |                      |             | Hastelloy C                             |
|          |      |            |          |           | 27   | Hastello         |           | Hastell |                      |             | Tantalum                                |
|          |      |            |          |           | 28   | Monel a          |           | Monel   |                      |             | Monel alloy                             |
|          |      |            |          |           |  | Code             | Relief va |         | ,                    |             | , |
|          |      |            |          |           |  | X0               | Vent val  | ve      |                      |             |   |
|          |      |            |          |           |  | X1               | Drain va  | lve     |                      |             |   |
|          |      |            |          |           |  |                  | Code      | Mount   | ing bracket          | t           |   |
|          |      |            |          |           |  |                  | В0        | Withou  | ıt mountin           | g bra       | cket                                    |
|          |      |            |          |           |  |                  | B1        | Tube b  | ending bra           | cket        |   |
|          |      |            |          |           |  | B2               |           |         | mounted b            | endi        | ng bracket                              |
|          |      |            |          |           |  | В3               |           |         | mounted flat bracket |             |   |
|          |      |            |          |           |  |                  |           | Code    |                      |             | cation certification                    |
|          |      |            |          |           |  |                  |           | E0      | No explos            |             |   |
|          |      |            |          |           |  |                  |           | E1      |                      |             | Exd II CT6                              |
|          |      |            |          |           |  |                  |           | E2      |                      |             | afe, Exia II CT4                        |
|          |      |            |          |           |  |                  |           |         | Code                 |             | ctrical connection                      |
|          |      |            |          |           |  |                  |           |         | D1                   |             | 0×1.5                                   |
| <b>D</b> |      |            | 3.5.4    | 0.0       |  | , , ,            | Di        |         | D2                   |             | er specified                            |
| DP       | A    | Н          | M1       | C1        | 21   | X0               | B1        | E1      | D1                   | Mo          | del No. Example                         |



# **HK76** Intelligent Monocrystalline Flat Diaphragm/Cylinder Flange Liquid Level Transmitter

## Measuring Range




| Range<br>code | Min<br>Range(KPa) | Max<br>Range(KPa) | Rated pressure (maximum) |
|---------------|-------------------|-------------------|--------------------------|
| В             | 1                 | 6                 |                          |
| С             | 6                 | 40                | Rated pressure of        |
| D             | 40                | 400               | liquid level flange      |
| Е             | 400               | 4000              |                          |

#### Comparison of relationship between flange and min range

| Liquid level flange | Nominal diameter | Minimum range |
|---------------------|------------------|---------------|
|                     | DN 50/2"         | 10КРа         |
| Flat Diaphragm type | DN 80/3"         | 1КРа          |
|                     | DN 100/4"        | 1KPa          |
|                     | DN 50/2"         | 16КРа         |
| Cylinder            | DN 80/2"         | 1KPa          |
|                     | DN 100/4"        | 1KPa          |

#### Dimensions





#### How to Order

| Code | Type |   |       |          |          |                         |          |             |             |          |        |                  |  |
|------|------|---|-------|----------|----------|-------------------------|----------|-------------|-------------|----------|--------|------------------|--|
| LT   |      | ntelligent Flat Diaphragm Flange Liquid Level Transmitter |       |          |          |                         |          |             |             |          |        |                  |  |
| СТ   |      | gent Cylinder Flange Liquid Level Transmitter             |       |          |          |                         |          |             |             |          |        |                  |  |
|      | Code |   |       | suring I |          |                         |          |             |             |          |        |                  |  |
|      | В    | 1~6   |       |          |          |                         |          |             |             |          |        |                  |  |
|      | C    | 6~40  |       |          |          |                         |          |             |             |          |        |                  |  |
|      | D    | 40~40   | 00    |          |          |                         |          |             |             |          |        |                  |  |
|      | E    | 400~4   |       |          |          |                         |          |             |             |          |        |                  |  |
|      |      | Code  |       | t Signal |          |                         |          |             |             |          |        |                  |  |
|      |      | Н   | 4~201 |          |          |                         |          |             |             |          |        |                  |  |
|      |      | S   |       | nA+Har   |          |                         |          |             |             |          |        |                  |  |
|      |      |   | Code  | Displa   |          |                         |          |             |             |          |        |                  |  |
|      |      |   | M1    | LCD      | <i>J</i> |                         |          |             |             |          |        |                  |  |
|      |      |   | M2    |          | (Low t   | emner:                  | ature re | sistant -   | 40°C )      |          |        |                  |  |
|      |      |   | 1.12  |          | ure ma   |                         | acure re | Sistaire    | 100         |          |        |                  |  |
|      |      |   |       | Code     |          | ge Mate                 | rial     | Code        | Diaphrag    | om       | Code   | Coating          |  |
|      |      |   |       | 22       | 3049     |                         | 77 7017  | N1          | 316L SS     | <b>5</b> | T1     | None             |  |
|      |      |   |       | 23       | 3169     |                         |          | N2          | Hastelloy   | v C      | T2     | PTFE             |  |
|      |      |   |       | 20       | 0100     |                         |          | N3          | Monel al    |          |        | 1112             |  |
|      |      |   |       |          |          |                         |          | N4          | Tantalun    |          |        |                  |  |
|      |      |   |       |          |          |                         |          | N5          | Titanium    |          |        |                  |  |
|      |      |   |       |          | Code     | Moun                    | ting Din | nensions    |             | 1        |        |                  |  |
|      |      |   |       |          | C1       | DN50                    | ting Din | ilciisioiis | )           |          |        |                  |  |
|      |      |   |       |          | C2       | DN80                    |          |             |             |          |        |                  |  |
|      |      |   |       |          | C3       | DN10                    |          |             |             |          |        |                  |  |
|      |      |   |       |          | C4       | 2"                      | 0        |             |             |          |        |                  |  |
|      |      |   |       |          | C5       | 3"                      |          |             |             |          |        |                  |  |
|      |      |   |       |          | C6       | 4"                      |          |             |             |          |        |                  |  |
|      |      |   |       |          | C7       |                         | pecified |             |             |          |        |                  |  |
|      |      |   |       |          | <u> </u> | Code                    | 1        |             | h (mm)      |          |        |                  |  |
|      |      |   |       |          |          | L10                     |          | flange)     | 11 (111111) |          |        |                  |  |
|      |      |   |       |          |          | L11                     | 50       |             |             |          |        |                  |  |
|      |      |   |       |          |          | L12                     | 100      |             |             |          |        |                  |  |
|      |      |   |       |          |          | L13                     | 150      |             |             |          |        |                  |  |
|      |      |   |       |          |          | LT                      |          | pecified    |             |          |        |                  |  |
|      |      |   |       |          |          |                         | Code     |             | ry length ( | (m)      |        |                  |  |
|      |      |   |       |          |          |                         | F0       | None        |             |          |        |                  |  |
|      |      |   |       |          |          |                         | F1       | 1m          |             |          |        |                  |  |
|      |      |   |       |          |          |                         | F2       | 2m          |             |          |        |                  |  |
|      |      |   |       |          |          |                         | F3       | 3m          |             |          |        |                  |  |
|      |      |   |       |          |          |                         | F4       | User sp     | ecified     |          |        |                  |  |
|      |      |   |       |          |          |                         |          | Code        | Mounting    | bracket  |        |                  |  |
|      |      |   |       |          |          |                         |          | A1          |             |          | racket |                  |  |
|      |      |   |       |          |          |                         |          |             |             |          |        |                  |  |
|      |      |   |       |          |          |                         |          |             |             |          |        |                  |  |
|      |      |   |       |          |          |                         |          |             |             |          |        |                  |  |
|      |      |   |       |          |          |                         |          |             | На          |          |        | fication (do not |  |
|      |      |   |       |          |          |                         |          |             | Code        |          |        |                  |  |
|      |      |   |       |          |          |                         |          |             |             |          |        |                  |  |
|      |      |   |       |          |          |                         |          |             |             |          |        |                  |  |
|      |      |   |       |          |          | A2 Tube bending bracket |          |             |             |          |        |                  |  |



| ĺ |    |   |   |    |    |    |     |    |    | E2 | Intrinsically safe,Exia II CT4 |                   |  |  |
|---|----|---|---|----|----|----|-----|----|----|----|--------------------------------|-------------------|--|--|
| ١ |    |   |   |    |    |    |     |    |    |    | Code Electrical connection     |                   |  |  |
| ١ |    |   |   |    |    |    |     |    |    |    | D1                             | M20×1.5           |  |  |
| ١ |    |   |   |    |    |    |     |    |    |    | D2                             | User specified    |  |  |
| 1 | LT | В | Н | M1 | 22 | C1 | L10 | F1 | A1 | E0 | D1                             | Model No. Example |  |  |

# **HK78** Intelligent Monocrystalline Dual-remote Flat Diaphragm/Cylinder Flange Liquid Level Transmitter



#### **Measuring Range**


| Range code | Min Range(KPa) | Max Range(KPa) | Rated pressure (max)           |  |
|------------|----------------|----------------|--------------------------------|--|
| В          | 1KPa           | 6КРа           |                                |  |
| С          | 6КРа           | 40КРа          | Rated pressure of liquid level |  |
| D          | 40KPa 400KPa   |                | flange                         |  |
| E          | 400KPa         | 4MPa           |                                |  |



#### Comparison of relationship between flange and min range

|                   |          | Min range                      |                               |  |  |  |  |  |  |
|-------------------|----------|--------------------------------|-------------------------------|--|--|--|--|--|--|
| Flange            | DN       | Unilateral remote transmission | Bilateral remote transmission |  |  |  |  |  |  |
|                   | DN 50/2" | 10КРа                          | 10КРа                         |  |  |  |  |  |  |
| Flat<br>Diaphragm | DN 80/3" | 6КРа                           | 1KPa                          |  |  |  |  |  |  |
| Diapinagin        | DN 4"    | 6КРа                           | 1KPa                          |  |  |  |  |  |  |
|                   | DN 50/2" | 10КРа                          | 10КРа                         |  |  |  |  |  |  |
| Cylinder          | DN 80/2" | 6КРа                           | 1KPa                          |  |  |  |  |  |  |
|                   | DN 4"    | 6КРа                           | 1KPa                          |  |  |  |  |  |  |

#### Dimensions





#### **How to Order**

| Code | Туре |  |                                 |                                      |          |          |          |                                     |      |         |  |  |  |
|------|------|--|---------------------------------|--------------------------------------|----------|----------|----------|-------------------------------------|------|---------|--|--|--|
| DY   |      | Intelligent remote differential pressure transmitter |                                 |                                      |          |          |          |                                     |      |         |  |  |  |
| GY   |      |  |                                 |                                      | nsmitter |          |          |                                     |      |         |  |  |  |
|      | Code |  | Pressure measurement range(KPa) |                                      |          |          |          |                                     |      |         |  |  |  |
|      | В    | 1~6  |                                 |                                      |          | -        |          |                                     |      |         |  |  |  |
|      | С    | 6~40   |                                 |                                      |          |          |          |                                     |      |         |  |  |  |
|      | D    | 40~25  |                                 |                                      |          |          |          |                                     |      |         |  |  |  |
|      | Е    | 250~4  |                                 |                                      |          |          |          |                                     |      |         |  |  |  |
|      |      | Code   | Output                          | Output<br>4~20mA                     |          |          |          |                                     |      |         |  |  |  |
|      |      | Н  | 4~20n                           |                                      |          |          |          |                                     |      |         |  |  |  |
|      |      | S  | 4~20n                           | 4∼20mA+Hart                          |          |          |          |                                     |      |         |  |  |  |
|      |      |  | Code                            | Displa                               | у        |          |          |                                     |      |         |  |  |  |
|      |      |  | M1                              | LCD                                  |          |          |          |                                     |      |         |  |  |  |
|      |      |  | M2                              | OLED(                                | Low temp | erature  | resistan | t -40℃)                             |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          |          | Structure material                  |      |         |  |  |  |
|      |      |  |                                 | Code                                 | Flange M | laterial | Code     | Diaphragm material                  | Code | Coating |  |  |  |
|      |      |  |                                 | 22 304 SS N1 316L SS T1              |          |          |          |                                     |      |         |  |  |  |
|      |      |  |                                 | 23                                   | PTFE     |          |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          | N3       | Monel alloy                         |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          | N4       | Tantalum                            |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          | N5       | Titanium                            |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          | N6       | PTFE sprayed                        |      |         |  |  |  |
|      |      |  |                                 |                                      | Code     |          | ing Dim  | ensions                             |      |         |  |  |  |
|      |      |  |                                 |                                      | C1       | DN50     |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      | C2       | DN80     |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      | C3       | DN100    | )        |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      | C4       | 2"       |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      | C5       | 3"       |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      | C6       | 4"       | · C: 1   |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      | C7       |          | pecified |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      |          | Code     |          | e transmission device               |      |         |  |  |  |
|      |      |  |                                 |                                      |          | Y0<br>Y1 |          | lat flange type<br>flat flange type |      |         |  |  |  |
|      |      |  |                                 |                                      |          | Y2       |          | cylinder flange type                |      |         |  |  |  |
|      |      |  |                                 |                                      |          | Y3       |          | - cylinder flange type              |      |         |  |  |  |
|      |      |  |                                 | Y4 One flat one cylinder flange type |          |          |          |                                     |      |         |  |  |  |
|      |      |  |                                 | Code   Capillary length              |          |          |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      |          | X0 1m    |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      |          | X1 2m    |          |                                     |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          | X2       | 3m                                  |      |         |  |  |  |
|      |      |  |                                 |                                      |          |          | X3       | User specified                      |      |         |  |  |  |
|      |      | X3 User specified                                    |                                 |                                      |          |          |          |                                     |      |         |  |  |  |

12

•www.holykell.com•

•Tel: +86 731 89873265 •E-mail: info@holykell.com •Fax: +86 731 89873646



#### PRESSURE MEASUREMENT

|    |   |   |    |                |    |    |    | Code | Cylind  | er lengt                      | h (mm                                    | )                        |  |  |
|----|---|---|----|----------------|----|----|----|------|---------|-------------------------------|--|--------------------------|--|--|
|    |   |   |    |                |    |    |    | 10   | 0(Flat  | 0(Flat flange)                |  |                          |  |  |
|    |   |   |    |                |    |    |    | 11   | 50      |                               |  |                          |  |  |
|    |   |   |    |                |    |    |    | 12   | 100     |                               |  |                          |  |  |
|    |   |   |    |                |    |    |    | 13   | 150     |                               |  |                          |  |  |
|    |   |   |    |                |    |    |    | T    | User sp | pecified                      |  |                          |  |  |
|    |   |   |    |                |    |    |    |      | Code    | Mount                         | ing brac                                 | cket                     |  |  |
|    |   |   |    |                |    |    |    |      | В0      | Without mounting bracket      |  |                          |  |  |
|    |   |   |    |                |    |    |    |      | B1      | Tube bending bracket          |  |                          |  |  |
|    |   |   |    |                |    |    |    |      | B2      | Board-mounted bending bracket |  |                          |  |  |
|    |   |   |    |                |    |    |    |      | В3      | Tube mounted flat bracket     |  |                          |  |  |
|    |   |   |    |                |    |    |    |      |         |                               | Hazardous location                       |                          |  |  |
|    |   |   |    |                |    |    |    |      |         | Code                          | Code   certification (do not fill in for |                          |  |  |
|    |   |   |    |                |    |    |    |      |         |                               | ordina                                   | ry type)                 |  |  |
|    |   |   |    |                |    |    |    |      |         | E0                            | None 6                                   | explosion-proof          |  |  |
|    |   |   |    |                |    |    |    |      |         | E1                            | Flame                                    | proof, Exd II CT6        |  |  |
|    |   |   |    |                |    |    |    |      |         | E2                            | Intrins                                  | sically safe,Exia II CT4 |  |  |
|    |   |   |    |                |    |    |    |      |         |                               | Code                                     | Electrical connection    |  |  |
|    |   |   |    |                |    |    |    |      |         |                               | D1                                       | M20×1.5                  |  |  |
|    |   |   |    |                |    |    |    |      |         |                               | D2                                       | User specified           |  |  |
| DY | В | Н | M1 | 22<br>N1<br>T1 | C1 | Y0 | X0 | 10   | В0      | E0                            | D1                                       | Model No. Example        |  |  |

13

•www.holykell.com•

•E-mail: info@holykell.com

•Tel: +86 731 89873265 •Fax: +86 731 89873646