



# **Liquid Turbine Flow Meter**

# **User Manual**





# **Content**

1.0 GENERAL INFORMATION	1
2.0 SPECIFICATIONS	
3.0 OPERATION CONDITIONS	3
4.0 CAUTIONS FOR INSTALLATION	5
5.0 DIMENSION	8
6.0 ELECTRICAL WIRING	.11
7.0 OPERATION AND SETUP	16
8.0 TROUBLESHOOTING	.19
9.0 METER CONSTRUCTION	. 20



## Warning

When the flow meter is installed at explosion hazard field, DON'T remove the COVERPLATE when the meter is powered. Please make parameter setting at safe filed prior to installation.



## **Special Notices**

Pictures & Descriptions are for your information only, please refer to the actual product. Parameters are subjected to changes without notice.



## 1.0 GENERAL INFORMATION

This manual will assist you in installing, using and maintaining your turbine flow meter. It is your responsibility to make that all operators have access to adequate instructions about safe operating and maintenance procedure.



#### Warning

For your safety, review the major warnings and cautions below before operating your equipment

Use only fluids that are compatible with the housing material and wetted components of your turbine.

During turbine removal, liquid may spill. Follow the liquid manufacturer's safety precautions for clean up of minor spills.

When measuring flammable liquids, observe precautions against fire or explosion.

Do not blow compressed air through the turbine.

When handling hazardous liquids, always follow the liquid manufacturer's safety precautions.

Handle the rotor carefully. Even small scratches or nicks can affect accuracy.

When working in hazardous environments, always exercise appropriate safety precautions.

When tightening the turbine, use a wrench only on the wrench flats .

For best results, calibrate the meter at least 1 time per year.

## **Product Description**

HLY series turbine flow meters have the features: high accuracy, good repeatability, convenient installation/maintenance, simple structure etc.

Liquid flows through the turbine housing causing an internal rotor to spin. As the rotor spins, an electrical signal is generated in the pickup coil. This signal is converted into engineering units (liters, cubic meters, gallons etc.) on the local display where is applicable. Optional accessory modules can be used to export the signal to other equipment.

Upon receipt, examine your meter for visible damage. The turbine is a precision measuring instrument and should be handled carefully. Remove the protective plugs and caps for a thorough inspection. If any items are damaged or missing, contact

Make the turbine flow model meets your specific needs. For your future reference, it might be useful to record this information on nameplate in the manual in case it becomes unreadable on the turbine. Refer to the nameplate for your customized product's specification.

1



## 2.0 SPECIFICATIONS

**Performance** 

Repeatability: ±0.2%

Accuracy: Standard: ±1% of reading;

Optional: ±0.5% of reading

**Wetted Components** 

Housing: Standard - 304 Stainless Steel

Optional - 316 Stainless Steel

Bearings and Shaft: Tungsten Carbide

Rotor: Standard - 2Cr13 Stainless Steel

(Optional Alloy CD4Mcu)

Retaining Rings: 316 Stainless Steel

**Output Signal:** (Where applicable)

Sensor: Pulse signal (Low Level: ≤0.8V; High Level: ≥8V)

Transmitter: 4 to 20 mA DC current signal

**Signal Transmission Distance:** ≤1,000 m

**Electrical Connections:** 

Basic Type: Hirschmann Connector or three-core cable

Explosion Proof Type: ISO M20×1.5 Female

**Explosion Proof Level:** 

Standard: None

Optional: ExdIIBT6

Protection Level: IP65



## 3.0 OPERATION CONDITIONS

#### **Ambient:**

Temperature: -10°C to +55°C

Pressure: 86 to 106 KPa

Relative Humidity: 5% to 90%

**Power Supply:** 

Sensor: +12V DC (Optional: +24V DC)

Transmitter: +24V DC

Field Display Type B: Integral 3.2V Lithium Battery (Others available on request)

Field Display Type C: +24V DC

**Fluid Temperature and Pres:** 

Temperature: -20°C to +110°C

Pres: Fluid pres should be limited according to rating.

#### Measurable Flow Rate Range and Pres Level: (See table 1)

Table 1. Measurable Flow Rage Range and Pressure Rating

Nominal Standard Flow Range (SFR)		Extended Flow Range (EFR)	Standard Pres Rating	Customized Pres Rating	
(mm)	(in.)	(m³/h)	(m³/h)	(MPa)	(MPa) - Flange Fitting
4	0.15	0.04 to 0.25	0.04 to 0.4	Thread: 6.3	12, 16, 25
6	0.25	0.1 to 0.6	0.06 to 0.6	Thread: 6.3	12, 16, 25
10	0.4	0.2 to 1.2	0.15 to 1.5	Thread: 6.3	12, 16, 25
15	0.5	0.6 to 6	0.4 to 8	Thread: 6.3; Flange: 2.5	4.0, 6.3, 12, 16, 25
20	0.75	0.8 to 8	0.45 to 9	Thread: 6.3; Flange: 2.5	4.0, 6.3, 12, 16, 25
25	1	1 to 10	0.5 to 10	Thread: 6.3; Flange: 2.5	4.0, 6.3, 12, 16, 25
32	1.25	1.5 to 15	0.8 to 15	Thread: 6.3; Flange: 2.5	4.0, 6.3, 12, 16, 25
40	1.5	2 to 20	1 to 30	Thread: 6.3; Flange: 2.5	4.0, 6.3, 12, 16, 25
50	2	4 to 40	2 to 40	Flange: 2.5	4.0, 6.3, 12, 16, 25
65	2.5	7 to 70	4 to 70	Flange: 2.5	4.0, 6.3, 12, 16, 25
80	3	10 to 100	5 to 100	Flange: 2.5	4.0, 6.3, 12, 16, 25
100	4	20 to 200	10 to 200	Flange: 1.6	4.0, 6.3, 12, 16, 25
125	5	25 to 250	13 to 250	Flange: 1.6	2.5, 4.0, 6.3, 12, 16
150	6	30 to 300	15 to 300	Flange: 1.6	2.5, 4.0, 6.3, 12, 16
200	8	80 to 800	40 to 800	Flange: 1.6	2.5, 4.0, 6.3, 12, 16



## **Model Selection**

HLY-	
Nominal diameter (mm)	
10	
Nominal diameter (mm)	
DN20	
Nominal diameter (mm)	
Nominal diameter (mm)	
diameter (mm)       40         50       50         65       50         80       50         100       50         125       50         150       50         200       50         FL       60         Connection       65         DN100       50         DN125       50         DN150       50         Flanged       50         Threaded       70	
(mm)       50         65       DN65         80       DN80         100       DN100         125       DN125         DN150       DN200         FL       Flanged         Connection       LW	
65   DN65   DN80   DN100   DN100   DN125   DN150   DN200   Flanged   Flanged   Threaded	
80   DN80   DN100   DN100   DN125   DN150   DN200   FL	
100     DN100   DN125   DN150   DN200   Flanged   Threaded   Threaded   Threaded   DN100   DN200   D	
125     DN125   DN150   DN200   FL Connection   LW   Threaded   Threaded   Connection   Connec	
150	
Z00 DN200 FL Connection LW Threaded	
Z00 DN200 FL Connection LW Threaded	
Connection LW Threaded	
Connection LW Threaded	
JZ J Clamp-on by flange	
N 24V power supply, no field display, pulse of	output
A 24V power supply, field display, 4-20mA o	•
G1 Battery powered, field display, no output	
External power supply field display	
Meter type GX RS485/current/pulse output	
(Explosion-proof type)Battery powered fi	eld
display, no output	
(Explosion-proof type) External power	
Supply, field display, RS485/current/pulse	output
05 Standard range	
Accuracy 10 Extended range	
O2 Special range	
S 0.5	
Range U 1.0	
Z 0.2(by customized, long production period	d)
304 \$\$	
Meter material  L  316(L) SS	
S 2Cr13 impeller	
Impeller material  L  Duplex steel impeller	
N Non-explosion proof	
Explosion-proof grade  Explosion-proof grade  Explosion-proof grade	
N Standard	
Temperature and pressure resistant $H(x)$ High pressure	

Notes: DN20,DN32,DN65,DN125 are custom. X refers to number(s), standing for different functions. Contact us for details.



## 4.0 CAUTIONS FOR INSTALLATION

#### **Mounting Positions**

Turbine flow meters should be installed at the place in compliance with the requirements below:

- ♦ Easy maintenance
- ♦ No vibration

- ♦ No electromagnetic interface
- Away from heat source

#### **Mounting Orientation**

All turbine flow meters are designed to measure flow in only one direction. The direction is indicated by the arrow on the body.

#### **Required Lengths of Straight Runs**

Flow altering device such as elbows, valves and reducers can affect accuracy. See diagram 1 for typical flow meter system installation.




Diagram 1. Typical Flow Meter System Installation


The recommended guidelines are given to enhance accuracy and maximize performance. Distance given here are minimum requirements; double them for desired straight pipe lengths.

- Upstream: allow a minimum straight pipe length at least 10 times the internal diameter of the pipe. For example, with the 50mm pipe, there should be 500mm of straight pipe immediately upstream.
   Desired upstream straight pipe length is 1000mm.
- Downstream: allow a minimum straight pipe length at least 5 times the internal diameter of the pipe.
   For example, with the 50mm pipe, there should be 250mm of straight pipe immediately upstream.
   Desired upstream straight pipe length is 500mm



See diagram 2 for straight pipe length requirement when there is altering device.

Diagram 2. Number of Pipe Diameter (D=Diameter)





**Warning:** Precaution for direct sunshine and rain when the meter is installed outside.

#### **Anti-Cavitation**

Cavitation can be caused by entrained air, and it can seriously damage the rotor on a turbine flow meter. An amount higher than about 100 mg/l of entrained air or gas can produce error. In addition, cavitations can be caused by too little back pres on the flow meter. For turbine flow meters, you should provide a back pres (downstream pres) of at least 1.25 times the vapor pres, plus 2 times the pressure drop through the flow meter. See formula 1.

Formula 1: 
$$P_b \ge 1.25 \times P_v + 2 \times (P_{in} - P_{out})$$
  
In formula 1:  $(P_b: Back pres; P_v: Vapor Pres; P_{in}: Inlet Pres; P_{out}: Outlet Pres)$ 

Create back pres by installing a control valve on the downstream side of the meter at the proper distance detailed above.



## **Special Notice**

- Foreign material in the liquid being mead can clog the meter's rotor and adversely affect accuracy. If this problem is anticipated or experienced, install screens to filter impurities from incoming liquids.
- ♦ To en accurate measurement, drain all air from the system before use.
- When the meter contain removable cover plates. Leave the cover plate installed unless accessory modules specify removal. Don't remove the cover plates when the meter is powered, or electrical shock and explosion hazard can be caused.



#### **Thread Connections**

- 1. To protect against leakage, seal all threads with an appropriate sealing compound. Make the sealing compound does not intrude into the flow path.
- 2. Make the arrow on the outlet is pointed in the direction of the flow.
- 3. Tighten the turbine onto the fittings. Use a wrench only on wrench flats.

#### **Flange Connections**

#### For standard product, the flange follows GB/T 9119-2000 (ISO 7005-1) RF (Raised Face).

Note: flange can be customized following other criteria.


Use a gasket between the meter flange and mating flange. Determine the material of the gasket based on the operating conditions and type of fluid.

Note: Do not over tighten the flange bolts. This may cause the gasket to be compressed into the flow stream and may decrease the accuracy of the meter.



## 5. INSTALLATION DIMENSIONS

Thread or flange connection is used according to different flow models.





## Threaded and flanged type of liquid turbine flow meter

# Threaded connection

	L		G			
DN(mm)	(mm) N1(Pulse)		N2(Pulse+4-20mA)/ A(4~20mA)	G(Intelligent)	E(Explosion-proof)	
4	225	145	145	190	210	G1/2
6	225	145	145	190	210	G1/2
10	345	150	150	190	210	G1/2
15	75	150	150	195	215	G1
20	85	155	155	200	220	G1
25	100	160	160	205	225	G11/4
32	140	180	180	225	245	G2
40	140	185	185	230	250	G2
50	150	190	190	235	255	G21/2

Note: for DN4~DN10, when connecting the filter, the overall length should be increased by 50mm on the basis of L..

## Flanged Connection

DN	L	D	К			р	n		
(mm)	(mm)	(mm)	(mm)	N1 (Pulse)	N2(Pulse+4-20mA)/ A(4~20mA)	G(Intelligent)	E(Explosion- proof)	(mm)	(Qty of holes)
15	75	95	65	175	180	225	245	14	4
20	80	105	75	185	190	235	255	14	4
25	100	115	85	200	195	240	260	14	4
32	140	140	100	210	215	260	280	18	4
40	140	150	110	195	220	265	285	18	4
50	150	165	125	230	235	280	300	18	4
65	170	185	145	255	260	305	325	18	4
80	200	200	160	260	265	310	330	18	8
100	220	220	180	285	285	330	350	18	8
125	250	250	210	310	315	360	380	18	8
150	300	285	240	345	345	390	410	22	8
200	350	340	295	395	400	445	465	22	12



## Wafer and clamp types of liquid turbine flow meter

	L		D					H(mm)			
DN(mm)	)		(mm)	N2(P	ulse+4-20	mA)	A(4~20m		igent)	E(Explo	sion-proof)
4	50	0	38					26!			215
6	50	0	38					26	5		215
10	50	0	38					26!	5		215
15	5.	5	47					27!	5		225
20	6	0	53					280	)		230
25	6	0	58					28!	5		235
32	32 70		66			Χ		290	)		240
40	7(	0	72					300	)		250
50	7(	0	92					31!	5		265
65	80	0	100		210		210	25!	5		275
80	9(	0	112		225		225	270	)		290
100	10	00	137		250		250	29!	5		315
125	12	20	165		275		275	320	)		340
150	15	0	190		300		300	34!	5		365
200	15	0	243		350		350	39!	5		415
DN(mm)	L(mm)	D(mm)	A(mm)	B(mm)	B(mm)	N2(Pu	ulse+4-20			lligent)	E(Explosion
							,				-proof)
											215
	50										215
											215
											225
	100	50.5	46	40.5							225
											230
				F0 -							230
									1		245
50	150	78	73.5	68	50		190	190		35	255
65	170	91	86	80.5	65		205	205		50	270
		106	100.5	94 106	80 100		220 240	220		65 85	285 305
80	200	127	113					2711			
	6 10 15 20 25 32 40 50 65 80 100 125 150 200	6 50 10 50 15 55 20 60 25 60 32 70 40 70 50 70 65 80 80 90 100 100 125 12 150 15 200 15  DN(mm) L(mm)  4 6 50 10 15 20 100 25 32 120	6 50 10 50 15 55 20 60 25 60 32 70 40 70 50 70 65 80 80 90 100 100 125 120 150 150 200 150   DN(mm) L(mm) D(mm) 4 6 50 10 15 20 100 50.5 32 120	6 50 38  10 50 38  15 55 47  20 60 53  25 60 58  32 70 66  40 70 72  50 70 92  65 80 100  80 90 112  100 100 137  125 120 165  150 150 190  200 150 243   DN(mm) L(mm) D(mm) A(mm)  4 6 50  10 15  20 100 50.5 46  25 32 120	6     50     38       10     50     38       15     55     47       20     60     53       25     60     58       32     70     66       40     70     72       50     70     92       65     80     100       80     90     112       100     100     137       125     120     165       150     150     190       200     150     243          DN(mm)     L(mm)     D(mm)     A(mm)     B(mm)       4     6     50       10     15       20     100     50.5     46     40.5       32     120	6     50     38       10     50     38       15     55     47       20     60     53       25     60     58       32     70     66       40     70     72       50     70     92       65     80     100     210       80     90     112     225       100     100     137     250       125     120     165     275       150     150     190     300       200     150     243     350          DN(mm)     L(mm)     D(mm)     A(mm)     B(mm)     B(mm)       4     6       10     15       20     100     50.5     46     40.5     20       25     32     120     32	6     50     38       10     50     38       15     55     47       20     60     53       25     60     58       32     70     66       40     70     72       50     70     92       65     80     100     210       80     90     112     225       100     100     137     250       125     120     165     275       150     150     190     300       200     150     243     350       A   6   6   10   15   15   15   15   15   15   15	6     50     38       10     50     38       15     55     47       20     60     53       25     60     58       32     70     66     X       40     70     72       50     70     92       65     80     100     210     210       80     90     112     225     225       100     100     137     250     250       125     120     165     275     275       150     150     190     300     300       200     150     243     350     350       DN(mm)     L(mm)     D(mm)     A(mm)     B(mm)     B(mm)     N2(Pulse+4-20 mA)       4     150     6     150       10     150     150     150     150       15     160     150     150     150     150       20     100     50.5     46     40.5     20     160       25     165     32     165     165	6       50       38         10       50       38         15       55       47         20       60       53         25       60       58         32       70       66         40       70       72         50       70       92         65       80       100       210       210       250         80       90       112       225       225       225       270         100       100       137       250       250       290         125       120       165       275       275       321         150       150       190       300       300       340         200       150       243       350       350       391	Column	Column



## **6.0** ELECTRICAL WIRING

**Warning: Electrical Hazard** 

Disconnect power before beginning installation.


**Turbine Flow Sensor/Transmitter** 


♦ 1. Pulse Type without Explosion Proof

Terminal wiring


Terminal Symbols	Description					
Red Wire	Power Supply: "24V+"					
White Wire	Power Supply: "24V-"					
Yellow Wire	Pulse Output					

♦ 2. Pulse with Explosion Proof:





- Notice: (1) High level amplitude >22V
  - (2) Low level amplitude<0.8V
  - (3) Load capacity>1100 $\Omega$
  - (4) Pulse frequency≤3000Hz
- ♦ 3. 4-20mA Output with Explosion Proof Type



Notice: Load resistor is <




## ◆ 4. Function table for the Intelligent display type

					Output				
Main Power				Current					
	Display	Pulse * 1	Scaled Pulse *2	2-wire 4~20 mA	3-wire 4-20 mA	4-wire 0 -20m	4-wire 4~20m A	Modbus RS485	
Battery*3	•	•							
24V DC	•	•	•	•	0			•	
24V C+Battery*4	•	•	•	•	0			•	
220Vac	•	•	•			0	•	•	
Description of the	symbols:		<ul><li>Def</li></ul>	ault Functi	on	0	Optional		

#### Notice:

- 1. The pulse means the signal which is in direct proportion to the impeller speed.
- 2. The scaled Pulse means the signal when the flow rate reach ONE unit volume( m3, L, 0.01L...)
- 3. The batter model is ER34615
- 4. The battery model is ER26500

#### 4.1 24V DC powered type




Terminal Configuration



## **Terminal Configuration**

Terminal No.	Terminal Symbols	Description
1	GND	24V- DC Power Supply
2	24V	24V+ DC Power Supply
3	Lout-	Current Output 4 to 20 mA DC (-)
4	Lout+	Current Output 4 to 20 mA DC (+)
5	GND	24V- DC Power Supply
6	-FOUT	F-OUT: Pulse output
7	485A	RS485-
8	485B	RS485+


## $4.1.1\,$ Pulse / Scaled Pulse output



Notice: (1) High level amplitude >22V


- (2) Low level amplitude<0.8V
- (3) Load capacity>1100Ω
- (4) Pulse frequency≤3000Hz

## 4.1.2 (2 Wire) 4-20mA Output






## 4.1.3 (3 Wire) 4-20mA Output




## 4.1.4 (3 Wire) 0-20mA Output




Notice: Load resistor is  $<500\Omega$ 

## 4.1.5 RS485 communication



Notice: The communication format is Modbus-RTU protocol

## 4.2 220Vac powered type




**Terminal Configuration** 



Terminal	Configuration	


Terminal No.	Terminal Symbols	Description
1	L	AC 220V Power Supply
2	N	AC 220V Power Supply
3	Lout-	Current Output
4	Lout+	Current Output
5	GND	Current / Pulse output -
6	FOUT	FOUT: Pulse output
7	485A	RS485-
8	485B	RS485+

## 4.2.1 Pulse / Scaled Pulse output




Notice: Three conditions are necessary for pulse output High level amplitude >22V Low level amplitude <0.8V Load capacity>1100 $\Omega$  Pulse frequency  $\leq$  3000H

#### 4.2.2 (4 Wire) 4-20mA Output




#### 4.2.3 (4 Wire) 0-20mA Output






#### 4.2.4 RS485 communication



#### 4.2.5 Function table for

DIP Switch: K1									
Function	1	2	3						
Original Pulse Output	ON	OFF	OFF						
Scaled Pulse Output: 1 m³ / Pulse	OFF	ON	OFF						
Function Reserved	OFF	OFF	ON						

## 7.0 Parameter set





# 7.1There are four keys: "Enter", " $\rightarrow$ ", " $\uparrow$ ", "Esc".

KEYS	Description			
Enter	Save the value and advance to next menu			
$\rightarrow$	For numerical values, move cursor position			
<b>1</b>	To change number unit, setting			
Esc	Return to measuring model			

## 7.2 Description of Password Grade

Password	Description			
1234	Modify parameters			
5555	Total rate reset			

## 7.3 Description of menu

Menu	Parameter	Setting Method	Grade	Description		
F-1 (	Unit	Select parameter	User	Value	Flow Unit	Total Flow Unit
				0	M3/h	M3
				1	L/h	L
				2	L/min	L
				3	US Gal/min	US Gal
				4	UK Gal/min	UK Gal
				5	US Gal/h	US Gal
				6	UK Gal/min	UK Gal



				7	KG/h	Kg	
				8	t/h	T	
				9	Ft3/h	Ft3	
				Unit: Second	FLS/II	FLS	
F-2	Damp time	Input value	User	Value: 0~99s			
F-3	Max flow rate	Input value	User	Unit: The same to the F-1			
F-4	Min flow rate	Input value	User	When the flow	rate lower than min	flow rate, the flow	
F-4	will now rate	input value	User	rate will display 0; The unit is the same to the F-1			
F-5	Max frequency output	Input value	User	Accuracy: 0.1Hz			
F-6	Density	Input value	User	When need to display mass unit, it needs to input the			
1-0	Delisity	•	0361	density of liquid. The unit of density is g/cm3			
F-7	Pulse output	Select	User	1: Original pulse output			
		parameter		2: Corrected			
			User	0.001: 0.01 uni			
		Select		pulse 0.01:0.01 unit volume /			
F-8	Scaled pulse	parameter		pulse 0.1: 0.1 unit volume /			
				pulse			
				1: 1 unit volume / pulse			
F-9	Pulse width	Input value	User			nge, and it's multiple	
		-	-	of 5 with ms ur			
F-10	Communication	Select	User	Address: 1-247			
		parameter		Baud rate: 1200, 2400, 4800, 9600, 19200			
		Select parameter	User	N( No verify)			
	Baud			O( Odd verify)			
F-11				E( Even verify)			
				Data length: 7,8			
				Stop bits length: 1,2			
F-12	Total flow	Input value	User	It could be modified with right code			
P1	Linearization of the	Input value	Factory			) without decimal, F1	
	Flowcurve: point 1	pat value	only	Second Row: Coefficient error with (K1) six decimals			
P2	Linearization of the	Input value Factory			Corrected Frequency (F2) without de		
	Flowcurve: point 2	•	only		Second Row: Coefficient error with (K2) six decimals		
Р3	Linearization of the	Input value	Factory	First Row: Corrected Frequency (F3) without decimal,			
	Flowcurve: point 3	-	only	Second Row: Coefficient error with (K3) six decimals			
P4	Linearization of the	Input value	Factory	First Row: Corrected Frequency (F4) without decimal, Second Row: Coefficient error with (K4) six decimals			
	Flowcurve: point 4		only				
P5	Linearization of the	Input value	Factory	First Row: Corrected Frequency (F5) without decimal, Second Row: Coefficient error with (K5) six decimals			
	Flowcurve: point 5 Linearization of the	Input value	only Factory		ected Frequency (F6	•	
P6	Flowcurve: point 6		only		oefficient error with		
	Linearization of the		Factory		ected Frequency (F7		
P7	Flowcurve: point 7	Input value	only		oefficient error with		
	Linearization of the		Factory		ected Frequency (F8		
P8	Flowcurve: point 8	Input value	only		oefficient error with		
	i lowcui ve. politico		Uilly			` ,	
5.5	0 1111	Input value	Factory only		ected Frequency wit		
P9	Coefficient				oetticient error with	two decimals, unit:	
				/L, K			




# 8.0 TROUBLESHOOTING

Symptom	Probable Cause	Solution		
Measurement is	1. Turbine operated below minimum	Increase flow rate. Refer to Section 3.0		
not accurate	rate.	Operation Conditions		
	, , ,	Remove turbine. Clean carefully. Make rotor spins freely.		
	3. Installed too close to fittings.	Install correctly. Refer to Section 5.0 Cautions for Installation		
LCD Display	1. Battery Power Type: Bad contact on	Open back cover and repower the flow		
Abnormality	the connector between battery and PCB	meter		
	2. DC Power Type: supply voltage is abnormal	Check and en power supply is 24V DC		



#### **METER CONSTRUCTION** 9.0





## **Limited Warranty Policy**

Hereby provides a limited warranty against defects in materials and workmanship. This product includes a one-year warranty. The warranty period shall begin on the date of the original new equipment purchase. Warrantor's obligation hereunder shall be limited to repairing defective workmanship or replacing or repairing any defective parts.

In the event Purchaser believes the product is defective, the product must be returned to, transportation prepaid by Purchaser, within the appropriate warranty period relative to the product. If 's inspection determines the workmanship or materials are defective and the required maintenance has been performed and, has been properly installed and operated, the product will be either repaired or replaced, at 's sole determination, free of additional charge, and the goods will be returned, transportation paid by , using a transportation method selected by .

Prior to returning the product to , Purchaser must obtain a Returned Material Authorization (RMA) Number from 's Customer Service Department within 30 days after discovery of a purported breach of warranty, but not later than the warranty period; otherwise, such claims shall be deemed waived.

If 's inspection reveals the product to be free of defects in material and workmanship or such inspection reveals the goods were improperly used, improperly installed,and/or improperly selected for service intended,will notify the purchaser in writing and will deliver the goods back to Purchaser upon receipt of Purchaser's written instructions and agreement to pay the cost of transportation. If Purchaser does not respond within thirty (30) days after notice from , the goods will be disposed of in 's discretion.

does not warrant the product to meet the requirements of any safety code or other jurisdiction, and Purchaser assumes all risk and liability whatsoever resulting from the use thereof, whether used singly or in combination with other machines or apparatus.

This warranty shall not apply to any product or parts thereof, which have been repaired outside 's factory or altered in any way, or have been subject to misuse, negligence, or accident, or have not been operated in accordance with 's printed instructions or have been operated under conditions more severe than, or otherwise exceeding, those set in the specifications.

FOR NON- WARRANTY REPAIRS OR CALIBRATIONS, consult for current repair/calibration charges. Have the following information available BEFORE contacting:

- 1.P.O. number to cover the COST of the repair/calibration,
- 2. Model and serial number of the product, and
- 3. Repair instructions and/or specific problems relative to the product.